

TIER 3 PUBLIC NOTICE
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Glen Canyon NRA Wahweap

Our water system violated drinking water standards over the past year and we are actively working to be held in good standing with no missing public information. Even though these were not emergencies, as our customers you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

During 2025 we did not complete all reporting for monitoring routine (DBP), major violation for TTHM and/or HAA5 issued within the last 12 months and therefore, are posting these violations.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants that were properly tested but not reported during the required time frames.

Contaminant	Required sampling frequency	Number of samples taken	When samples were taken	MCL violation
Nitrate	Annual	1	06/10/2025	Yes
DBP	Annual	4	7/10/25 & 11/13/2025	Yes

What is being done?

We are now scheduled to monitor DBP's quarterly and have established a monthly water flushing routine to eliminate stale water in dead end sections of the distribution system. We post this notice in good faith acknowledging these violations.

For more information, please contact Ky Mack-Borhauer (928) 614-9197 or PO Box 1507, Page Arizona 86040.

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Glen Canyon NRA Wahweap
State Water System ID#: AZ0403712
Date distributed: 1/12/2026