

## JEFF CAR 2015 Design Review Team S106 Meeting Notes

**Meeting #30:** April 22, 2015  
**Time:** 9-10 CT

### I. Attendees

Role	Name	Participated
DRT Member	Tom Bradley	X
DRT Member	Maggie Hales	X
DRT Member	Vern Remiger	X
DRT Member	Judith Deel	X
DRT Member	Toni Prawl	X
DRT Member	Bill Hart	
DRT Member	Karen Bode Baxter	
DRT Member	Kathryn Thomas	X
Facilitator	Margo Brooks	X
Great River Greenways	Lonny Boring	X
CAR2015	Anna Leavey	X
JEFF	Ed Dobbs	X
JEFF	Kathy Schneider	X
NPS-DSC	Emmeline Morris	X

### II. Temporary Lift at Old Courthouse

Emmeline Morris presented information on a contractor proposal to move the current accessible lift to the opposite side of the portico during construction of the moats and new accessible ramps. The contractor believes that the proposal will shorten construction time and save money. The change will entail the cutting of an historic railing that will be replaced after the ramps are built and the lift removed. A temporary sidewalk to the lift would also need to be built and removed at the end of the project. The lift would not need to attach to the portico.

Kathryn Thomas shared the information with the park CRM Team and read the following comment received from Al O'Bright.

The only comment I've got concerns the OCH west portico historic railing that are being removed & reinstalled upon completion of the ramp project. Ensure the railings are carefully removed to prevent damage. Verify the railings can be effectively welded (are they of cast or wrought iron or steel?) and the weld joint smoothly ground out and to match the surface level and texture of the surrounding historic material upon reinstallation.

After discussing the project, the DRT agreed that there was no objection to the proposal, providing that O'Bright's conditions were carried out.

### III. Drinking Fountains

Vern Remiger provided a short presentation on the replacement of the drinking fountains. The design initially approved by the DRT was found not to meet ADA standards for cane detection because the bowls projecting on each side are too high. If the drinking fountain were placed in an alcove or in a bump out outside of the path in

areas where people would not be likely to run into it, it would be acceptable. Because it is within the path it is not. The new design was presented. Because the CLR states the current drinking fountains are not character-defining and can be replaced with a modern, compatible fountain, it was found to be acceptable, although not as attractive as the first choice. The new fountains will be coated with a matt finish to match the light posts.

The DRT had no objection to this change.

**IV. Park DRT Membership**

The DRT park representative to replace Ann Honious is Kathryn Thomas.

**V. Future DRT Meeting Dates**

May 27, 2015 @ 9AM Central